

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1273:103 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: Digital Security Control, 95 Bridgeland Ave., Toronto, Ontario, Canada M6A 1Y7*
Contact: Dan Nita (905) 760-3000 FAX (905) 760-3020

DESIGN: Models PC1500, PC1550 and P-6 combination household fire and burglary alarm control units. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

PC1500/PC1550/P-6	Control Units
PC1500RK/PC1500RKF	Keypad
LCD-600, PRS6L	Keypad
RK6, APS, PC1550RK	Keypad

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire alarm control units for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to listee's Installation Instructions Manual for details.

NOTE:

1. For household system, **Fire Alarm Verification Feature** (delay of fire alarm signal) is NOT approved for use in California.
2. Burglary and other non-fire functions were not examined.

*Rev. 06-15-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 22, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**